

# OMARA SB



# Protocol

Certificate of Equivalency of  
OMARA NG / OMARA SB,  
modified with anti humidity protection filter HF3

## Objective:

To highlight the equivalence of performance of audio transmission between **OMARA NG** and **OMARA SB**, modified with filter HF3

These measurements intend to clarify the following question :

“Does the addition of the filter AudioService HF3 in the audio output channel modify the characteristics of audio transmission of OMARA?”

## General principles

Tests are carried out according to the measurement procedure of “Performances of the hearing aid”, CIS 118-7 normalizes (2005)


### – Material and method

A hearing aid, model Phonak Exélia Art P, serial number 0937X0WCX, was used as a measurement standard gauge. It was programmed using the software Phonak iPFG in “TEST” mode according to characteristics “FOG (Full On Gain) /Microphone

This hearing aid was settled in a acoustical test chamber “ Measuring equipment Audio Aurical Diagnosis Fitting System of the company Madsen, calibration METAS A04, validity 04/12”

The device is the HIT Modulates (Hearing Instrument Test Modulates)

## Schematic diagram of the Aurical Test Chamber



# Protocol

Certificate of Equivalency of  
OMARA NG / OMARA SB,  
modified with anti humidity protection filter HF3

## **Measurements process**

The aim is to carry out a comparative analysis of "the hearing aid gauge"  
according to two experimental conditions

- Without filter HF3

(Corresponding by analogy to **OMARA NG**): Measure **PILOT**

- With filter HF3

(Corresponding by analogy to **OMARA SB**): Measure **TEST**

### **Measure PILOT:**

The hearing aid gauge is displayed in the acoustical test chamber at the central point of a measurement target printed on the floor of the test box

The hearing aid is connected to a coupler  $2\text{cm}^3$ , which is linked to the measuring microphone. A plastic tube ensures the connection between the hearing aid and the coupler  $2\text{cm}^3$

A reference microphone is placed 5 mm apart from the hearing aid gauge microphone as to secure the emission of stable acoustic pressure levels

The test box is overlaid by a loudspeaker

#### *Signal test description :*

Sweep Start frequency                      200 Hz

Sweep Stop frequency                        8000Hz

Stimulus Type :                                pure tone modulated (Warble tones)

Stimulus Accuracy :    0.7dB

Frequency resolution :        24 pts/octave

#### *Two measurements are tested:*

▶ A measurement "OSPL90" giving a maximum output level

▶ A measurement "full gain" giving a maximum gain and an input average gain of 50dB SPL.

### **Measure TEST:**

Identical to the measure PILOT apart from the following point:

A filter HF3 AudioService is placed at the end of the plastic tube. (See diagram)



# Protocol

Certificate of Equivalency of  
OMARA NG / OMARA SB,  
modified with anti humidity protection filter HF3

## Results

– Measure PILOT :  
Curve patient : HF3 OMARA NG  
OSPL90  
Maximum output : 129.9dB  
at frequency 1000Hz  
  
HFA (High Frequency Average) : 125.5 dB  
(1000, 1600, 2500 Hz)  
  
Full gain  
Maximum gain 54.5dB  
at frequency 1900 Hz  
Average at 50dB 48.1dB

– Measure TEST  
Curve patient : HF3 OMARA SB  
OSPL90  
Maximum output: 129.4dB  
at frequency 950 Hz  
  
HFA (High Frequency Average) 125.7dB  
(1000, 1600, 2500 Hz)  
  
Full gain  
Maximum gain 54.6dB  
at frequency  
Average at 50dB 48.1dB

## Conclusion

According to the results of the Measure PILOT and Measure TEST pointing out a difference of 0.7dB at output max HFA and an average full gain with equality, we can conclude at an audio performance equivalence between **OMARA NG** and **OMARA SB**.


## Résultats test prothèses

Les résultats des tests non-standard

Patient: Erika Test

Patient No: 007001412000WC App. auditif: Exélia Art P  
0937X0WCX

Oreille: Droite



### To the question:

“Does the addition of the filter AudioService HF3 in the audio output channel modify the characteristics of audio transmission of **OMARA**?”

### The answer is:

The filter AudioService HF3 has a non-significant influence on the audio performances of **OMARA**.

# OMARA SB

general description and main technical features

